



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

December 29, 2020

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX: (541) 830-6375

RE: Lower Table Rock Elementary

Order No.: 20120794

Dear John Harding:

Neilson Research Corporation received 63 sample(s) on 12/15/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 20120794
Date: 12/29/2020

CLIENT: Eagle Point School District #9

Project: Lower Table Rock Elementary

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-01 Client Sample ID: Room 1 S
 Collection Date: 12/15/2020 5:04:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 1 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.51		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-02 Client Sample ID: Room 1 Ftn
 Collection Date: 12/15/2020 5:05:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 1 Ftn

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	21.7	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-03 Client Sample ID: Room 2 S
 Collection Date: 12/15/2020 5:00:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 2 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	68.2	*	0.100	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-04 Client Sample ID: Room 2 F
 Collection Date: 12/15/2020 5:02:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 2 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	32.9	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-05 Client Sample ID: Room 3 S
 Collection Date: 12/15/2020 5:06:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 3 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	64.6	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-06 Client Sample ID: Room 3 F
 Collection Date: 12/15/2020 5:07:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 3 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	22.0	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-07 Client Sample ID: Room 4 S
 Collection Date: 12/15/2020 5:09:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 4 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	36.9	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-08 Client Sample ID: Room 4 F
 Collection Date: 12/15/2020 5:10:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 4 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	23.3	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-09 Client Sample ID: Room 5 S
 Collection Date: 12/15/2020 5:12:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 5 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	16.8	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-10 Client Sample ID: Room 5 F
 Collection Date: 12/15/2020 5:13:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 5 F

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.94		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-11 Client Sample ID: Room 6 S
 Collection Date: 12/15/2020 5:17:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 6 S

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.77		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-12 Client Sample ID: Room 6 F
 Collection Date: 12/15/2020 5:18:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 6 F

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.07		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-13 Client Sample ID: Room 7 S
 Collection Date: 12/15/2020 5:55:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 7 S

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	11.1		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-14 Client Sample ID: Room 7 F
 Collection Date: 12/15/2020 5:56:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 7 F

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.69		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-15 Client Sample ID: Room 8 S
 Collection Date: 12/15/2020 5:58:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 8 S

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.56		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-16 Client Sample ID: Room 8 F
 Collection Date: 12/15/2020 5:59:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 8 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.98		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-17 Client Sample ID: Room 9 S
 Collection Date: 12/15/2020 6:03:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 9 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	21.7	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-18 Client Sample ID: Room 9 F
 Collection Date: 12/15/2020 6:04:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 9 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.23		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-19 Client Sample ID: Room 10 S
 Collection Date: 12/15/2020 6:05:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 10 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	70.1	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-20 Client Sample ID: Room 10 F
 Collection Date: 12/15/2020 6:06:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 10 F

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.21		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-21 Client Sample ID: Room 11 S
 Collection Date: 12/15/2020 6:07:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 11 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.50		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-22 Client Sample ID: Room 11 F
 Collection Date: 12/15/2020 6:08:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 11 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	10.1		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-23 Client Sample ID: Room 12 S
 Collection Date: 12/15/2020 6:10:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 12 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.1		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-24 Client Sample ID: Room 12 F
 Collection Date: 12/15/2020 6:11:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 12 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	11.0		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-25 Client Sample ID: Room 13 S
 Collection Date: 12/15/2020 5:30:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 13 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	90.5	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-26 Client Sample ID: Room 13 F
 Collection Date: 12/15/2020 5:31:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 13 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	19.9	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-27 Client Sample ID: Room 14 S
 Collection Date: 12/15/2020 5:34:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 14 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	103	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-28 Client Sample ID: Room 14 F
 Collection Date: 12/15/2020 5:35:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 14 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	36.9	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-29 Client Sample ID: Room 16 S
 Collection Date: 12/15/2020 5:38:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 16 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.40		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-30 Client Sample ID: Room 16 F
 Collection Date: 12/15/2020 5:39:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 16 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	28.7	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-31 Client Sample ID: Room 17 S
 Collection Date: 12/15/2020 5:41:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 17 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	56.7	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-32 Client Sample ID: Room 17 F
 Collection Date: 12/15/2020 5:42:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 17 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	51.6	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-33 Client Sample ID: Room 18 S
 Collection Date: 12/15/2020 5:44:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 18 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	33.5	*	0.100	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-34 Client Sample ID: Room 18 F
 Collection Date: 12/15/2020 5:45:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 18 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	17.8	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-35 Client Sample ID: Room 19 S
 Collection Date: 12/15/2020 5:47:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 19 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	23.6	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-36 Client Sample ID: Room 19 F
 Collection Date: 12/15/2020 5:48:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 19 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.3		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-37 Client Sample ID: Room 20 S
 Collection Date: 12/15/2020 5:50:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 20 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	159	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-38 Client Sample ID: Room 20 F
 Collection Date: 12/15/2020 5:51:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 20 F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	41.8	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-39 Client Sample ID: Room 21 S
 Collection Date: 12/15/2020 5:53:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 21 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	65.5	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-40 Client Sample ID: Room 21 F
 Collection Date: 12/15/2020 5:54:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Room 21 F

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	67.3	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-41 Client Sample ID: Wrk Rm GRRS
 Collection Date: 12/15/2020 5:20:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Wrk Rm GRRS

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	18.5	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-42 Client Sample ID: Wrk Rm BRRS
 Collection Date: 12/15/2020 5:21:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Wrk Rm BRRS

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.70		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-43 Client Sample ID: Loni's Office S
 Collection Date: 12/15/2020 6:28:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Loni's Office S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	26.7	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-44 Client Sample ID: IARM S
 Collection Date: 12/15/2020 5:23:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: IARM S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	25.6	*	0.100	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120794-45 Client Sample ID: Staff WRRS
 Collection Date: 12/15/2020 5:25:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Staff WRRS

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.62		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-46 Client Sample ID: Staff MRRS
 Collection Date: 12/15/2020 5:26:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Staff MRRS

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.99		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-47 Client Sample ID: Drk Fountain Tall
 Collection Date: 12/15/2020 6:29:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Drk Fountain Tall

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	35.1	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-48 Client Sample ID: Drk Fountain Short 8
 Collection Date: 12/15/2020 6:30:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Drk Fountain Short 8

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	35.0	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-49 Client Sample ID: Tiger Store S
 Collection Date: 12/15/2020 6:31:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Tiger Store S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	320	*	1.00	µg/L	10	12/19/2020	15.0	A	

Lab ID: 20120794-50 Client Sample ID: PE RR S
 Collection Date: 12/15/2020 6:33:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: PE RR S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.74		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-51 Client Sample ID: K1 Boys RR #1 S
 Collection Date: 12/15/2020 6:25:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: K1 Boys RR #1 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.4		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-52 Client Sample ID: K1 Boys RR #2 S
 Collection Date: 12/15/2020 6:26:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: K1 Boys RR #2 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	18.9	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-53 Client Sample ID: K1 Girls RR #1 S
 Collection Date: 12/15/2020 6:23:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: K1 Girls RR #1 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.80		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-54 Client Sample ID: K1 Girls RR #2 S
 Collection Date: 12/15/2020 6:24:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: K1 Girls RR #2 S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	22.8	*	0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-55 Client Sample ID: 2G Boys RR #1 S
 Collection Date: 12/15/2020 6:19:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: 2G Boys RR #1 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.30		0.103	µg/L	1	12/18/2020	15.0	A

Lab ID: 20120794-56 Client Sample ID: 2G Boys RR #2 S
 Collection Date: 12/15/2020 6:20:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: 2G Boys RR #2 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.69		0.103	µg/L	1	12/18/2020	15.0	A

Lab ID: 20120794-57 Client Sample ID: 2G Girls RR #1 S
 Collection Date: 12/15/2020 6:17:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: 2G Girls RR #1 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.41		0.103	µg/L	1	12/18/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-58 Client Sample ID: 2G Girls RR #2 S
 Collection Date: 12/15/2020 6:18:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: 2G Girls RR #2 S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	85.1	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-59 Client Sample ID: Health Room S
 Collection Date: 12/15/2020 6:20:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Health Room S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	35.7	*	0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120794-60 Client Sample ID: Kitchen Sink DW
 Collection Date: 12/15/2020 5:30:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Kitchen Sink DW

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.06		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120794
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120794
Received Date: 12/15/2020 1:05:00 PM
Reported Date: 12/29/2020 11:53:01 AM

Sample Information:

Lab ID: 20120794-61 Client Sample ID: 3 Sink Back
 Collection Date: 12/15/2020 5:32:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: 3 Sink Back

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.15		0.103	µg/L	1	12/18/2020	15.0	A

Lab ID: 20120794-62 Client Sample ID: Hand Wash Sink
 Collection Date: 12/15/2020 5:33:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: Hand Wash Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.13		0.103	µg/L	1	12/18/2020	15.0	A


Lab ID: 20120794-63 Client Sample ID: RR Kitchen S
 Collection Date: 12/15/2020 5:35:00 AM Collected By: Loni O Connor
 Matrix: Drinking Water Sample Location: RR Kitchen S

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.73		0.103	µg/L	1	12/18/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120794
 29-Dec-20

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-10121	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10121	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 258992						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.103									

Sample ID: LCS-10121	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10121	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 258993						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.7	0.104	100	0	98.7	85	115				

Sample ID: 20120794-02AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Room 1 Ftn	Batch ID: 10121	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 258997						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	119	0.104	100	21.7	97.0	70	130				

Sample ID: 20120794-02AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Room 1 Ftn	Batch ID: 10121	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 258998						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	117	0.104	100	21.7	95.7	70	130	119	1.06	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120794
 29-Dec-20

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-10122	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10122	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259017						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10122	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10122	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259018						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.104 100 0 100 85 115

Sample ID: 20120794-46AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Staff MRRS	Batch ID: 10122	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259042						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 105 0.104 100 7.99 96.9 70 130

Sample ID: 20120794-46AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Staff MRRS	Batch ID: 10122	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259043						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 107 0.104 100 7.99 98.6 70 130 105 1.65 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120794
 29-Dec-20

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-10123	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259046						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10123	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259047						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.8 0.104 100 0 99.8 85 115

Sample ID: 20120794-47AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Drk Fountain Tall	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259049						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 132 0.104 100 35.1 97.3 70 130

Sample ID: 20120794-47AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: Drk Fountain Tall	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259050						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 133 0.104 100 35.1 97.9 70 130 132 0.431 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120794
 29-Dec-20

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-10144	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: PBW	Batch ID: 10144	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259867						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.100									

Sample ID: LCS-10144	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: LCSW	Batch ID: 10144	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259868						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.1	0.100	100	0	99.1	85	115				

Sample ID: 20121013-01AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: BatchQC	Batch ID: 10144	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259873						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	92.3	0.100	100	0.154	92.1	70	130				

Sample ID: 20121013-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: BatchQC	Batch ID: 10144	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259874						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	89.8	0.100	100	0.154	89.6	70	130	92.3	2.78	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120794
 29-Dec-20

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-10142	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: PBW	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259877						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.100

Sample ID: LCS-10142	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: LCSW	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259878						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 198 0.100 200 0 99.0 85 115

Sample ID: 20120794-03AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: Room 2 S	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259880						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 254 0.100 200 68.2 92.7 70 130 E

Sample ID: 20120794-03AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: Room 2 S	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259881						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 261 0.100 200 68.2 96.6 70 130 254 3.02 20 E

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	




Original

Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **20120794**

RcptNo: **1**

Logged by:	Naomi Orr	12/15/2020 1:05:00 PM	
Completed By:	Krizzle Calip	12/16/2020 8:21:27 AM	
Reviewed By:	Naomi Orr	12/29/2020 11:34:18 AM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
Custody seals intact on shipping container/cooler? Yes No Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No HNO3 pH<2
No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

The sample submitted was tan in color (fraction 38,37,39,40,41,and 44) and contained visible sediments (fraction 02, 03, 05, 07, 09, 13, 21, 23, 25, 27, 28, 29, 30, 31, 37, 42, 43, 44, 45, 49, 51, 52, 53, 54, 58, 59, 61, and 62).

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point S.D. # 9</u>	Project Name: <u>Lower Table Rock Elem.</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding.T@EaglePnt. K12. OR. US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-838-6376</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>Loni Oconnor</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Rm 1 S. 85254			12/15/20	5:04	Lead			01
Rm 1 ftw. 85184				5:05				02
Rm 2 S. 85168				5:00				03
Room 2 F. 85143				5:02				04
Room 3 S. 85117				5:06				05
Room 3 F. 85138				5:07				06
Room 4 S. 85343				5:09				07
Room 4 F. 85150				5:10				08
Room 5 S. 85345				5:12				09
Room 5 F. 85153			12/15/20	5:13				10

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:13</u>
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:13</u>
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By:				
Relinquished By:				
Received By Laboratory: <u>[Signature]</u>		<u>Naomi Orr</u>	<u>12-15-2020</u>	<u>13:05</u>

Section G
Lab Use Only

Temp: Amb
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 63
 pH Checked: NIA
 COC Seals Intact: Yes No N/A
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Pt. SD# 9</u>	Project Name: <u>Lower Table Rock Stem</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding J @ EaglePt. K12.or.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>41-830-7316</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>Loni Oconnor</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Rm 6 S. 45268			12/15/20	5:17	Lead			11
Rm 6 F. 85306				5:18				12
Rm 7 S. 85165				5:55				13
Rm 7 F. 85323				5:56				14
Rm 8 S. 85145				5:58				15
Rm 8 F. 85344				5:59				16
Rm 9 S. 85231				6:03				17
Rm 9 F. 45244				6:04				18
Rm 10 S. 85288				6:05				19
Rm 10 F. 85258			12/15/20	6:06				20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
	<u>[Signature]</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:13</u>
Received By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:13</u>
Relinquished By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By:				
Relinquished By:	<u>[Signature]</u>	<u>Neomi Orr</u>	<u>12-15-20</u>	<u>1305</u>
Received By Laboratory:				

Section G
Lab Use Only

Temp: Amb
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 63
 pH Checked: N/A
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>546 Pt. St #9</u>	Project Name: <u>Lower Table Rock EL</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding@546PtSt.K12.0r.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-830-6376</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>Loni Oconnor</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers <u>Lead</u>	Analysis Requested							NRC Workorder # <u>20120794</u> (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected									Remarks/Field Data	NRC Sample # (Lab Use Only)
Rm 11 S.			12/15/20	6:07										21
Rm 11 F.				6:08										22
Rm 12 S.				6:10										23
Rm 12 F.				6:11										24
Rm 13 S.				5:30										25
Rm 13 F.				5:31										26
Rm 14 S.				5:34										27
Rm 14 F.				5:35										28
Rm 16 S.				5:38										29
Rm 16 F.			12/15/20	5:39										30

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive			
Relinquished By:	Sign	Print	Date
Relinquished By:	<u>[Signature]</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>
Received By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>
Relinquished By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>
Received By:			
Relinquished By:			
Received By Laboratory:	<u>[Signature]</u>	<u>Naomi Orr</u>	<u>12-15-20 13:05</u>

Section G Lab Use Only	
Temp:	<u>4mb</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>63</u>
pH Checked:	<u>N/A</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point SD #9
 Address: 283 N. Platt
Eagle Point OR 97524
 Email: Harding J @ Eagle Pnt. K12, Or. US
 Phone: 541-830-6376 Fax: _____
 Collected By (Print): Loni Oconnor
 Collected By (Sign): [Signature]
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B

Required Project Information

Project Name: Liner Table Rock El.
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
Rm 17 S.			12/15/20	5:41	Lead			31
Rm 17 F.				5:42				32
Rm 18 S.				5:44				33
Rm 18 F.				5:45				34
Rm 19 S.				5:47				35
Rm 19 F.				5:48				36
Rm 20 S.				5:50				37
Rm 20 F.				5:51				38
Rm 21 S.				5:53				39
Rm 21 F.			12/15/20	5:54				40

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:14</u>
Received By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:14</u>
Relinquished By:	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By:				
Relinquished By:	<u>[Signature]</u>	<u>Naomi Orr</u>	<u>12-15-2020</u>	<u>13:05</u>
Received By Laboratory:				

Section G

Lab Use Only

Temp: amb
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 63
 pH Checked: NIA
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point SD #9
 Address: 203 N. Platt
Eagle Point OR 97524
 Email: harding@eaglept.k12.or.us
 Phone: 541-831-6316 Fax: _____
 Collected By (Print): Loni Oconnor
 Collected By (Sign): [Signature]
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B

Required Project Information

Project Name: Lower Table Pk
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)			
Wrk Rm G PPS. 85230			12/15/20	5:20	lead														41	
Wrk Rm B PPS. 85342			↓	5:21															42	
Loni's office S. 85245				6:28																43
I Arm, S. 85340				5:23																44
Staff W PPS. 85316				5:25																45
Staff M PPS. 85229				5:26																46
Drk fountain Tall 85294				6:29																47
Drk FIN Short 85236				6:30																48
Tiger Store S. 85255				6:31																49
P.E. RR S. 85228				12/15/20		6:33														50

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished/Received By	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:15</u>
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:15</u>
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By: _____	_____	_____	_____	_____
Relinquished By: _____	_____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	<u>Monu Orr</u>	<u>12-15-2020</u>	<u>13:05</u>

Section G

Lab Use Only

Temp: Amb
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 63
 pH Checked: N/A
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>Lowertable Rock EL.</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding@EaglePt. K12.N.J.S</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-830-6376</u> Fax:			<input type="checkbox"/> Other
Collected By (Print): <u>Loni Oconnor</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>(Signature)</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
<u>K1 Boys RR#1 S. 85255</u>			<u>12/15/20</u>	<u>6:25</u>	<u>Lead</u>			<u>51</u>
<u>K1 Boys RR#2 S. 85336</u>				<u>6:26</u>				<u>52</u>
K1 Boys RR#1 S. 85315								<u>5354 error No 12-15-2020</u>
<u>K1 girls RR#1 S. 85315</u>				<u>6:23</u>				<u>53</u>
<u>K1 girls RR#2 S. 85289</u>				<u>6:24</u>				<u>54</u>
<u>2g. Boys RR#1 S. 85237</u>				<u>6:19</u>				<u>55</u>
<u>2g. Boys RR#2 S. 85348</u>				<u>6:20</u>				<u>56</u>
<u>2g girls RR#1 S. 85332</u>				<u>6:17</u>				<u>57</u>
<u>2g girls RR#2 S. 85269</u>				<u>6:18</u>				<u>58</u>
<u>Health Room S. 85265</u>			<u>12/15/20</u>	<u>6:20</u>				<u>59</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>(Signature)</u>	<u>(Signature)</u>	<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:15</u>
Received By: <u>(Signature)</u>	<u>(Signature)</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:15</u>
Relinquished By: <u>(Signature)</u>	<u>(Signature)</u>	<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By:				
Relinquished By:				
Received By Laboratory: <u>(Signature)</u>	<u>(Signature)</u>	<u>Naomi Orr</u>	<u>12-15-2020</u>	<u>13:05</u>

Section G

Lab Use Only

Temp: NIA

4°C +/- 2°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 63

pH Checked: NIA

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Eagle Point SD 9</u>		Project Name: <u>Lower Table Rock</u>		Attention:		<input checked="" type="checkbox"/> Standard 10-14 Days	
Address: <u>203 N. Platt Ave</u>		Project Number:		Company Name:		<input type="checkbox"/> 5 Business Days (50% surcharge)	
<u>Eagle Point OR 97524</u>		Report To:		Address:		<input type="checkbox"/> 3 Business Days (75% surcharge)	
Email: <u>Hardingj@EaglePt.k12.or.us</u>		Copy To:		P.O. #		<input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						<input type="checkbox"/> Other _____	
Collected By (Print): <u>Loni Oconnor</u>						Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Collected By (Sign): _____							
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No					
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # <u>20120794</u> (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
<u>Ktchn. Sink DW 85224</u>				<u>5:30</u>	<u>lead</u>											<u>60</u>	
<u>3 sink Back 85313</u>				<u>5:32</u>													<u>61</u>
<u>Hand Wash Sink 85273</u>				<u>5:33</u>													<u>62</u>
<u>RR Kitchen S. 85272</u>				<u>5:35</u>													<u>63</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>Loni Oconnor</u>	<u>12/15/20</u>	<u>12:15</u>
Received By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/15</u>	<u>12:15</u>
Relinquished By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/15</u>	<u>1:05</u>
Received By:	<u>[Signature]</u>				
Relinquished By:	<u>[Signature]</u>				
Received By Laboratory:	<u>[Signature]</u>		<u>Abomi Orr</u>	<u>12-15-2020</u>	<u>1305</u>

Section G Lab Use Only	
Temp: <u>AMB</u>	
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>63</u>	
pH Checked: <u>N/A</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>XNA</u>	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

- B Analyte detected in the associated method blank.
- BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- D1 The diesel elution pattern for the sample is not typical.
- D2 The sample appears to be a heavier hydrocarbon range than diesel.
- D3 The sample appears to be a lighter hydrocarbon range than diesel.
- D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
- D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- G1 The gasoline elution pattern for the sample is not typical.
- G2 The sample appears to be a heavier hydrocarbon range than gasoline.
- G3 The sample appears to be a lighter hydrocarbon range than gasoline.
- G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- NLR No Legionella Recovered.
- PLR Presence of Legionella Recovered.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 Duplicate analysis failed due to result being at or near the method reporting limit.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- # Value exceeds regulatory level for TCLP contaminant.
- X1 The motor oil elution pattern for the sample is not typical.
- X2 The sample appears to be a heavier hydrocarbon range than motor oil.
- X3 The sample appears to be a lighter hydrocarbon range than motor oil.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.