

Radon Tests - White Mountain Middle School

Location	Placement Description	Serial #	Date Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
101		9175871	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
101A		9175804	3/15/2019	9:00 AM	3/18/2019	9:00 AM	20.9 ± 1.3	
102		9175866	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
103		9175864	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
103 Office		9175863	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
103-2		9175865	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
104		9175862	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
105		9175861	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
106		9175850	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
106-2		9175867	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
107		9175870	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
107-2		9175849	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.5 ± 0.3	
108		9175869	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
109		9175868	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Art Room		9175839	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Avid Office		9175842	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.8 ± 0.3	
Avid Room		9175841	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Ball Room		9175846	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Band Room		9175845	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Band Room -2		9175854	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Boiler Room		9175844	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.7 ± 0.3	
Conference Room		9175851	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.7 ± 0.3	
Conference Room -2		9175856	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Custodian Closet		9175857	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.5 ± 0.3	
Disciplinarian Office		9175860	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
Gym 1		9175872	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Gym 2		9175873	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Health		9175848	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Library		9175855	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Library Office		9175858	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.5 ± 0.3	
Main Office		9175852	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Plant Engineer Office		9175853	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.5 ± 0.3	

Plant Engineer Shop		9175840	3/17/2019	9:00 PM	3/20/2019	9:00 PM	0.7 ± 0.3	
Principal's Office		9175847	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
SBHC Counselor		9175859	3/17/2019	10:00 PM	3/20/2019	9:00 PM	<0.3	
Staff Room		9175843	3/17/2019	9:00 PM	3/20/2019	9:00 PM	<0.3	
Type	Description	Serial #	Date Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
Spike #1 - 101A		9175804	3/15/2019	9:00 AM	3/18/2019	9:00 AM	20.9 ± 1.3	