

**Radon Tests - Eagle Rock Elementary School**

Location	Placement Description	Serial #	Date Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
2		9175891	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
4		9175884	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
4-2		9175885	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
5		9175886	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.5 ± 0.3	
6		9175887	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
7		9175888	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
12		9175881	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
12-2		9175882	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
13		9175883	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
13-2		7245445	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
14		7245444	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
15		7245443	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
15A		9175805	3/15/2019	9:00 AM	3/18/2019	9:00 AM	21.2 ± 1.3	
Calm Down Room		9175893	3/17/2019	8:00 PM	3/20/2019	8:00 PM	????IF1	Destroyed by student
Calm Down Room		7245449	4/15/2019	7:00 AM	4/17/2019	3:00 PM	1.2	Replacement
Conference Room		9175900	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.7 ± 0.3	
Custodian Closet		9175876	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Gym 1		9175896	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.5 ± 0.3	
Gym 2		9175897	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Health Room		9175890	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.8 ± 0.3	
Kindergarten		9175879	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Kindergarten -2		9175880	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Kitchen Storage		9175894	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.1 ± 0.3	
Main Office		9175877	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
Media Center		9175874	3/17/2019	8:00 PM				Missing after test
Media Center		7245446	4/15/2019	7:00 AM	4/17/2019	3:00 PM	0.6	Replacement
Media Center		7245447	4/15/2019	7:00 AM	4/17/2019	3:00 PM	<0.3	Duplicate
Media Center		4245448	4/15/2019	7:00 AM	4/17/2019	3:00 PM	<0.3	Blank
Media Center Office		9175875	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Owls Nest		9175898	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.9 ± 0.3	
Plant Engineer Shop		9175895	3/17/2019	8:00 PM	3/20/2019	8:00 PM	<0.3	
Principal's Office		9175889	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
Speech Office		9175892	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.8 ± 0.3	

Staff Room		9175899	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
Teachers Coach Office		9175878	3/17/2019	8:00 PM	3/20/2019	8:00 PM	0.6 ± 0.3	
Type	Description	Serial #	Date Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
Spike #1 - 15A		9175805	3/15/2019	9:00 AM	3/18/2019	9:00 AM	21.2 ± 1.3	